









Wall-mounted Controller and Sensor TRI2-FA

The TRI2 is a programmable controller and sensor with communication capabilities. Each control loop may use 2 PI sequences and 2 binary stages. The TRI2 uses the universal X2 operating system. Serial communication options are realized with Modbus RTU/ASCII and BACnet MS/TP over RS485. There is also a Wi-Fi communication option available which supports Modbus TCP and BACnet IP. An embedded webserver provides a web interface to operate the controller or change the connection settings. Complete parameter sets may be copied by use of an accessory called AEC-PM2 or exchanged with a PC using an RS485-USB converter or Wi-Fi communication, the EasySet program and the configuration adapter called AEC-TRI-2.

Applications

- Ventilation control
- Temperature control
- Zone control
- Air humidifier and dehumidifier

Functions

- Two universally configurable control loops:
 - Functions for dehumidifying, set point shift and cascade control
 - Multiple auxiliary functions: heat-cool auto changeover, automatic enable, set point compensation
 - Free heating and cooling with economizer function based on enthalpy or temperature
 - Differential, averaging, min and max functions, enthalpy and dew point calculations
 - Transmitter function for inputs and set points
- Built in humidity and temperature sensors (-TH type) or temperature sensor (-T type)
- 2 passive inputs (NTC, open contact), 1 analog input (VDC) and 2 analog outputs (VDC) 2 relays with a normally open contact (SPST NO) to switch line voltage
- 8 freely assigned alarm conditions, selectable state of outputs on alarm condition
- Power Cap protected real-time clock with 48hr power backup
- 7-day programmable schedules, with options including change of set points and direct position of manual outputs
- Password protected programmable user and control parameters
- Measures temperature and humidity
- Communication over Modbus, BACnet or Wi-Fi (optional interface required)
- Webserver that supports TRI2 operation trough browser or mobile devices (Wi-Fi interface required)

Types and Ordering

| Product Name | Product No. | Loop | UI | DO | AO | Functions |
|-------------------------|-------------|------|----|----|----|--|
| TRI2-FA-TH-221.202C | 40-100223 | 2 | 3 | 2 | 2 | |
| TRI2-FA-TH-221.202C-MOD | 40-100224 | 2 | 3 | 2 | 2 | |
| TRI2-FA-TH-221.202C-BAC | 40-100225 | 2 | 3 | 2 | 2 | T = Temperature sensor |
| TRI2-FA-TH-221.202C-WIM | 40-100235 | 2 | 3 | 2 | 2 | TH = Temperature- and humidity sensor |
| TRI2-FA-TH-221.202C-WIB | 40-100253 | 2 | 3 | 2 | 2 | MOD = Communication with Modbus RTU or ASCII |
| TRI2-FA-T-221.202C | 40-100232 | 2 | 3 | 2 | 2 | BAC = Communication with BACnet MS/TP |
| TRI2-FA-T-221.202C-MOD | 40-100233 | 2 | 3 | 2 | 2 | WIM = Communication with Modbus TCP over Wi-Fi |
| TRI2-FA-T-221.202C-BAC | 40-100234 | 2 | 3 | 2 | 2 | WIB = Communication with BACnet IP over Wi-Fi |
| TRI2-FA-T-221.202C-WIM | 40-100241 | 2 | 3 | 2 | 2 | |
| TRI2-FA-T-221.202C-WIB | 40-100254 | 2 | 3 | 2 | 2 | |

Accessories

| Product Name | Product No. | Description | |
|---------------------|-------------|--|--|
| AEC-PM2 | 40-500130 | Plug-In memory module for fast copying of parameter sets | |
| AEC-TRI-2 | 40-500154 | Configuration adapter with cable | |
| AEC-USB-01 | 40-500046 | USB to RS-485 converter cable kit for EasySet tool (only for device without Wi-Fi) | |



Safety



DANGER! Safety advice

This device is for use as an operating controller or sensor. It is not a safety device. Where a device failure could endanger human life and property, it is the responsibility of the client, installer and system designer to add additional safety devices to prevent such a device failure. Ignoring specifications and local regulations may cause equipment damage and endangers life and property. Tampering with the device and misapplication will void warranty.


Technical specifications

| Power supply | | Operating voltage | 24 VAC ±10%, 50/60 Hz, 1534 VDC | |
|------------------------|--------|---|---|--|
| | | Power consumption | Max. 10 VA | |
| | | Safety extra-low voltage (SELV) | HD 384, class II | |
| Built in | | Temperature sensor | NTC (Tn10 B25/50: 3935, 10kΩ@25 °C) | |
| sensors | | Range | 050 °C (32122 °F) | |
| (Type) | -TH | Measuring accuracy | 0.5 °C (1 °F) | |
| | | Repeatability | ± 0.1 °C, ± 0.2 °F | |
| | | Humidity sensor | Capacity sensor element 0100% RH | |
| | | Range Measuring accuracy | See Figure 1 | |
| | | Hysteresis | ± 1% | |
| | | Repeatability | ± 0.1% | |
| | -TH | Stability | < 0.5% / year | |
| | | Temperature sensor | Bandgap sensor | |
| | | Range | 050 °C (32122 °F) | |
| | | Measuring accuracy | See Figure 2 | |
| | | Repeatability | ± 0.1°C (± 0.2°F) | |
| Signal inp | uts | Passive input | UI4 to UI5, Passive Temperature NTC or open contact | |
| | | Type | NTC (Sxx-Tn10) 10kΩ@25 °C -40100 °C (-40212 °F) | |
| | | Range | UI6, in Voltage mode | |
| | | Analog input Type & range | 0 – 10 VDC | |
| | | Resolution | 9.76 mV (10 Bit) | |
| Signal out | touts | Analog output | AO1 to AO2 | |
| o.ga. out | .pu.co | Output signal | 010 VDC | |
| | | Resolution | 9.76 mV | |
| | | Maximum load | ≥1kΩ | |
| | | Relay outputs: AC Voltage | 0250 VAC, full-load current 1.2 A | |
| | | (SPST NO) DC Voltage | 030 VDC, full-load current 2 A | |
| | | Insulation strength between relays contacts | | |
| | | and system electronics: | 1500 VAC to EN 60 730-1 | |
| | | between neighboring contacts: | 1000 VAC to EN 60 730-1 | |
| Electrical connections | | Connector type | Screw terminal connectors for wire 0.341.3 mm2 | |
| Connection | 115 | | (AWG 2216) | |
| | | Remote terminal | RS485 in accordance with EIA/TIA 485, Shielded twisted pair cable | |
| Environme | ont | Operation | To IEC 721-3-3 | |
| LIIVII OIIIII | CIIL | Climatic conditions | Class 3K5 | |
| | | Temperature | 050 °C (32122 °F) | |
| | | Humidity | <85 % RH non-condensing | |
| | | Transport & storage | To IEC 721-3-2 and IEC 721-3-1 | |
| | | Climatic conditions | Class 3K3 and Class 1K3 | |
| | | Temperature | 050 °C (32122 °F) | |
| | | Humidity | <95 % RH non-condensing | |
| | | Mechanical conditions | Class 2M2 | |
| Standards | 5 | Degree of protection | IP30 to EN 60 529 | |
| | | Pollution class | II (EN 60 730-1) | |
| | | Safety class | II (IEC 60536) | |
| | | Overvoltage category | II (EN 60 730-1) | |
| General | | Material | Flame retardant PC+ABS plastic (UL94 class V-0) | |
| | | Dimensions (L x W x H) | Front part: 88 x 88 x 14 mm (3.5 x 3.5 x 0.6 in) Power Case: 50 x 50 x 31 mm (2.0 x 2.0 x 1.2 in) | |
| | | Weight (including package) | 184g (6.5 oz) | |
| | | J - (J | | |



Humidity and Temperature Sensor

Relative humidity absolute accuracy %RH ±5 ±4 ±3 ±2 ±1 ±0 0 10 20 30 40 50 60 70 80 90 100 %RH Figure 1: Max RH-tolerance at 25 °C (77 °F) per sensor type



Note on accuracy: allow one hour after power up for compensation swing in

Temperature Compensation

The TRI2 has a built-in temperature compensation algorithm to compensate for the internal heat of the product electronics. The compensation value may vary depending on the installation and wall structure and it can be corrected in order to match the temperature and humidity.

Procedure:

- 1. Startup the device and wait > 90 minutes for the device to warm up and for the compensation algorithm to complete. Make sure the environment is stable (windows closed).
- 2. Use the parameter "xu06 of the temperature input (default SI1 \rightarrow 1u06) for compensation. Example: 1u06 = 10: The temperature reading will increase 1.0°C



The humidity sensor does not need to be compensated because it is automatically adjusted based on the temperature calibration. Just make sure the temperature reading is accurate.



Technical specification for serial communication -MOD and -BAC types

| - | | · · |
|------------------|--|---|
| Network | Hardware interface Max nodes per network Max nodes per segment | RS485 in accordance with EIA/TIA 485 128 64 (Vector devices only) |
| | Conductors Impedance Nominal capacitance | Shielded Twisted Pair (STP) cable 100 - 130 ohm 100 pF/m 16 pF/ft. or lower |
| | Galvanic isolation | The communication circuitry is isolated |
| | Line termination | A line termination resistance (120 ohm) shall be connected between the terminals (+) and (-) of the furthermost node of the network |
| | Network topology | Daisy chain according EIA/TIA 485 specifications |
| | Recommended maximum length per chain | 1200 m (4000 ft.) |
| Modbus | Communication standard | Modbus (www.modbus.org) |
| (-MOD) | Default setting | 19200 baud rate, RTU 8 data bits, 1 even parity bit, 1 stop bit |
| | Communication speed | 4800, 9600, 19200, 38400 |
| | Protocol: Data bits Parity – stop bit | RTU - 8 data bits, ASCII - 7 data bits, no parity - 2 stops, even or odd parity - 1 stop |
| BACnet (-BAC) | Communication standard | BACnet MS/TP over RS485 BTL tested and listed B-ASC |
| BIL | Communication speed | 9600, 19200, 38400, 57600, 76800, 115200 |

Technical specification for TCP/IP communication -WIM and -WIB types


| • | • | -, -, - |
|---------------------|------------------------|---|
| Wi-Fi | Standards | Wi-Fi Alliance FCC/CE-RED/IC/TELEC/KCC/SRRC/NCC 802.11 b/g/n (802.11n up to 150 Mbps) A-MPDU and A-MSDU aggregation and 0.4 µs guard interval support |
| | Frequency range | 2.4 GHz ~ 2.5 GHz |
| | Antenna | Internal |
| Modbus TCP | Standard | IEC 61158 |
| (-WIM) | Communication protocol | Modbus TCP (<u>www.modbus.org</u>) |
| | Transport Layer | TCP/IP |
| | TCP/IP Port | 502 |
| BACnet/IP (-WIB) | Communication standard | BACnet/IP BTL tested and listed B-ASC |
| p.T. | Transport Layer | UDP |
| RIL | UDP Port | 47808 |

Product testing and certification



Declaration of Conformity Information on the conformity of our products can be found on our website www.vectorcontrols.com on the corresponding product page under "Downloads".

Dimension, mm (inch)





Mounting and Installation

Mounting location

- On a flat, easily accessible wall
- The following mounting locations should be avoided:
 - o Protect from direct exposure to sunlight
 - Do not install near heat sources or other heat-generating devices
 - o Areas with poor air circulation and niches
 - o In the direct influence area of ventilation and fans
 - For the types with wireless transmission (-WIM or -WIB), avoid locations that interfere with the radio signals, e.g. metal boxes or devices that generate electrical interferences.

Mounting instructions



See the TRI2-FA installation sheet, document no. 70-00-0730 (www.vectorcontrols.com).

Selection of sensors and actuators

▲ Temperature sensors

Use Vector Controls NTC sensors to achieve maximum accuracy: SDB-Tn10-20 (duct), SRA-Tn10 (room), SDB-Tn10-20 + AMI-S10 as immersion sensor.

▲ Actuators


Choose modulating actuators with an input signal type of 0/2-10 VDC.

3-point actuators with constant running time are recommended.

Binary auxiliary devices (e.g. pumps, fans, on/off valves, humidifiers, etc.)

Do not directly connect devices that exceed specified limits in technical specifications – observe startup current on inductive loads.

Connection diagram



Wire type

An EIA-485 network shall use shielded, twisted-pair cable for data signaling with characteristic impedance between 100 and 130 ohms. Distributed capacitance between conductors shall be less than 100 pF per meter (30 pF per foot). Distributed capacitance between conductors and shield shall be less than 200 pF per meter (60 pF per foot). Foil or braided shields are acceptable.

Maximum length

The maximum recommended length per segment is 1200 meters (4000 feet) with AWG 18 (0.82 mm2 conductor area) cable.

Status-LED

The TRI2 has a status-LED which becomes visible by removing the front part. The location of the LED is described in the installation sheet. The function of the LED is explained in the X2 operation manual.



Operation and Configuration

▲ Documentation

This controller uses the latest generation X2 operating system. Detailed operation instructions for all devices equipped with this operating system can be found on our website.

Also available are programming instructions for technicians and an application database.

▲ Configuration



The device can be fully configured and commissioned using the EasySet program or the built-in operation terminal.

EasySet may be downloaded free of charge from our website www.vectorcontrols.com.

Configuring the TRI2 device

▲ Configuring with EasySet (free PC application)

Use the PC and the EasySet tool to easily configure the TRI2 to your needs. Connect the PC with the EasySet tool ether with the AEC-USB converter and the AEC-TRI-2 configuration adapter to the TRI2 or use the Wi-Fi communication of the PC to connect to the TRI2 (for TRI2-WIM /-WIB devices only). See TRI2 installation sheet for connection details.



▲ Configuring with Operation Terminal

You can use the built-in operation terminal to configure the TRI2 to your needs. See "X2 Operations Manual touch display" and "X2 Engineering Manual" for details.

Copy Configuration to other TRI2 devices

Complete parameter sets may be copied using the accessory AEC-PM2 or exchanged with a PC using the EasySet tool and an RS485-USB converter or via Wi-Fi communication.



AEC-PM2

▲ Copy configuration with the AEC-PM2

Use the configuration adaptor ACE-TRI-2 to load the configuration onto the AEC-PM2 plug-in memory (see TRI2 installation sheet for connection details).

To copy the configuration to other TRI2 devices, connect the AEC-PM2 plug-in memory to the TRI2 and simply press the copy button (see TRI2 installation sheet for connection details).



▲ Copy configuration with EasySet (free PC application)

To copy the configuration to other TRI2 devices, connect the PC with the EasySet tool ether with the AEC-USB converter and the AEC-TRI-2 configuration adapter to the TRI2 or use the Wi-Fi communication of the PC to connect to the TRI2 (for TRI2-WIM /-WIB devices only). See TRI2 installation sheet for connection details.

Documentation overview

| Document Type | Document No. | Description |
|--|--------------|---|
| TRI2-FA Data Sheet | 70-00-0749 | Product data sheet (this document) |
| TRI2-FA Install Sheet | 70-00-0730 | Mounting and installation manual |
| X2 Operations Manual touch display | 70-00-0951 | Operations instructions of X2 system with touch display |
| X2 Web Interface operation manual | 70-00-0952 | Operations instructions of X2 Web interface |
| X2 Engineering Manual | 70-00-0737 | Guidelines for configuring the X2 system |
| X2 Modbus Communication Module (-MOD type) | 70-00-0290 | Setup and configuration manual Modbus (no Modbus TCP) |
| X2 Modbus Communication Module (-WEM type) | 70-00-0925 | Setup and configuration manual Modbus TCP |
| X2 BACnet Communication Module (-BAC type) | 70-00-0218 | Setup and configuration manual BACnet (no BACnet/IP) |
| X2 BACnet/IP Communication Module (-WEB type) | 70-00-0899 | Setup and configuration manual BACnet/IP |
| X2 Wi-Fi / Ethernet Communication Manual (-WEM, -WEB type) | 70-00-0900 | Setup and configuration manual TCP/IP |

Note: The above list is not complete. The documents on the website are relevant.



BACnet Protocol Implementation Conformance Statement (PICS)

BACnet MS/TP network

(i)

The following is only valid for products with the -BAC type option.

Vendor Name: Vector Controls Product Name: TRI2 Controls series

TRI2 product description: The TRI2 communicating BACnet controllers are designed as universal controls equipment

suitable for a large number of applications. They may be used in zoning and other applications

which are monitored by a BACnet MS/TP network.

▲ Supported BACnet Interoperability Blocks (BIBB)

The BACnet interface conforms to the B-ASC device profile (BACnet Application Specific Controller). The following BACnet Interoperability Building Blocks (BIBB) is supported.

| BIBB | Туре | Name |
|----------|-------------------|----------------------------------|
| DS-RP-B | Data sharing | Read property - B |
| DS-RPM-B | Data sharing | Read property multiple - B |
| DS-WP-B | Data sharing | Write property - B |
| DM-DCC-B | Device management | Device communication Control - B |
| DM-DDB-B | Device management | Dynamic device binding - B |
| DM-DOB-B | Device management | Dynamic object binding - B |
| DM-TS-B | Device management | Time synchronisation - B |
| DM-UTC-B | Device management | UTC Time synchronisation - B |
| DM-RD-B | Device management | Reinitialize device - B |

▲ Supported standard BACnet application services

- ReadProperty
- ReadPropertyMultiple
- WriteProperty
- DeviceCommunication (password protected)
- I-Am
- I-Have
- TimeSynchronisation
- UTCTimeSynchronisation
- ReinitializeDevice ("cold" or "warm") (password protected)

Supported standard Object types

- Device
- Analog input
- Analog value
- Binary value
- Multi-state Value

BACnet/IP communication



The following is only valid for products with the **-WIB** type option.

Vendor Name: Vector Controls
Product Name: TRI2 Controls series

TRI2 product description: The X2 communicating BACnet/IP controllers are designed as universal controls equipment

suitable for a large number of applications. They may be used in zoning and other applications

which are monitored by a BACnet/IP network.

▲ Supported BACnet Interoperability Blocks (BIBB)

The BACnet interface conforms to the B-ASC device profile (BACnet Application Specific Controller). The following BACnet Interoperability Building Blocks (BIBB) is supported.

| BIBB | Туре | Name |
|----------|-------------------|----------------------------------|
| DS-RP-B | Data sharing | Read property - B |
| DS-RPM-B | Data sharing | Read property multiple - B |
| DS-WP-B | Data sharing | Write property - B |
| DS-COV-B | Data sharing | Change of value - B |
| DM-DCC-B | Device management | Device communication Control - B |
| DM-DDB-B | Device management | Dynamic device binding - B |
| DM-DOB-B | Device management | Dynamic object binding - B |



| BIBB | Туре | Name |
|----------|-------------------|------------------------------|
| DM-TS-B | Device management | Time synchronisation - B |
| DM-UTC-B | Device management | UTC Time synchronisation - B |
| DM-RD-B | Device management | Reinitialize device - B |

▲ Supported standard BACnet application services

- ReadProperty
- ReadPropertyMultiple
- WriteProperty
- ChangeOfValue
- DeviceCommunication (password protected)
- I-Am
- I-Have
- TimeSynchronisation
- UTCTimeSynchronisation
- ReinitializeDevice ("cold" or "warm") (password protected)

▲ Supported standard Object types

- Device
- Analog input
- Analog value
- Binary value
- Multi-state Value
- Network Port

X2 Functional Scope

The controller supports the following X2 functions and elements:

| Group | Modules | QTY | Description |
|-------|--------------|-----|--|
| UP | - | - | User and display parameters |
| | 01U to 03U | 3 | Sensor inputs for temperature and humidity |
| UI | 04U to 06U | 3 | Universal inputs for RT/DI, mA, VDC |
| | 07U to 10U | 4 | Virtual inputs for operation terminals, bus modules or special functions |
| AL | 1AL to 8AL | 8 | Alarm conditions |
| LP | 1L to 2L | 2 | Control loops |
| AO | 1A to 2A | 2 | Analog outputs for mA, VDC |
| FAN | 1F | 1 | Fan or lead lag modules, 1 to 3 fan speeds, up to 3 switching lead-lag stages each |
| DO | 1d to 2d | 2 | Binary outputs with a normally open (NO) relays contact |
| | 1FU | 1 | Remote Enable: Activation of the controller based on signal and alarm conditions |
| | 2FU | 1 | Change Operation Mode: Switching occupied and unoccupied with control signals |
| FU | 3FU | 1 | Heat/Cool Change: Switching heating and cooling based on a control signal |
| | 4FU | 1 | Setpoint Compensation: Summer/winter compensation of setpoint |
| | 5FU | 1 | Economizer (free heating or cooling due to the condition of outside and room air) |
| CO | - | - | Communication (if a communication module is available) |
| COPY | - | - | Copying complete parameter sets between run, default and external memory with up to 4 memory locations (AEC-PM2) |
| RTC | - | 1 | Real time clock module with 48-hour power back up (keeps clock running during power failure) |
| PRO | Pr01 to Pr12 | 12 | Time schedule programs for 7 days or annual switching events |



More detailed information on the X2 functions can be found in the "X2 Engineering Manual" on our website www.vectorcontrols.com.





Empty page.



Smart Sensors and Controls Made Easy!

Quality - Innovation - Partnership

Vector Controls GmbH Switzerland

info@vectorcontrols.com www.vectorcontrols.com

